

**NC204**

10g ss pan head screws with  
30mm min embedment

H3.2 vertical timber batten  
\*See note

Rigid Air Barrier

15mm profiled closed cell foam  
insert end caps to suit profile of  
cladding

**NC105X + NC103**

Extended jointer cap over Jointer  
base

2.8x50mm hot dipped  
galvanised clout nails into  
framing @ 600 centers.  
(SS for Exposure Zone D)

**NC 204**

10g ss csk screws with 30mm  
min embedment

Allow 6mm gap between vertical  
and horizontal battens

**NC250**

Square termination flashing.

**NC 220**

15x15mm closed-cell foam insert

**NC226**

Impervious barrier (MDPE or similar)  
between batten & cladding

Drained and vented cavity as  
per E2/AS1

Direction of installation

## Cavity batten note:

- 20mm single castellated timber battens required for all Nu-Wall installations.
- Batten to have 15° slope for moisture egress
- Allow 6mm gap between vertical and horizontal battens
- Sill and head battens to be max. 500mm with a 6mm gap to each segment
- 18mm single castellated battens are available from Nu Wall for all vertical applications to wall junctions and jambs
- Proprietary Nu-Wall Alibat is available as an alternative when a structural non-combustable cavity batten is required



**nu-wall**  
CLADDING

## Nu-Wall cladding vertical on cavity

## Vertical Join - Mixed cladding NC105X-NC103

© 2021 copyright in this document is the property of Nu-Wall Aluminium Cladding Limited. All rights reserved. Nu-Wall is a registered trademark of Aluminium Product Brands NZ Limited

NW-VOC-043b.02

Drawn by: Nu-Wall

Date: 02/07/2025

Checked by: RL, GT

Scale: 1:2 @ A4