

NC204

10g ss pan head screws with
30mm min embedment

H3.2 vertical timber batten
*See note

15mm profiled closed cell foam
insert end caps to suit profile of
cladding

NC249

Top hat section along vertical join

NC250

Square termination flashing.

NC 204

10g ss csk screws with 30mm
min embedment

NC 220

15x15mm closed-cell foam insert

2.8x50mm hot dipped galvanised
clout nails into framing @ 600
centers.
(SS for Exposure Zone D)

NC226

Impervious barrier (MDPE or similar)
between batten & cladding

Drained and vented cavity as
per E2/AS1

Direction of installation

Allow 6mm gap
between vertical and
horizontal battens

Cavity batten note:

- 20mm single castellated timber battens required for all Nu-Wall installations.
- Batten to have 15° slope for moisture egress
- Allow 6mm gap between vertical and horizontal battens
- Sill and head battens to be max. 500mm with a 6mm gap to each segment
- 18mm single castellated battens are available from Nu Wall for all vertical applications to wall junctions and jambs
- Proprietary Nu-Wall Alibat is available as an alternative when a structural non-combustable cavity batten is required



nu-wall
CLADDING

Nu-Wall cladding vertical on cavity

Vertical Join - Mixed cladding

© 2021 copyright in this document is the property of Nu-Wall Aluminium Cladding Limited. All rights reserved. Nu-Wall is a registered trademark of Aluminium Product Brands NZ Limited

NW-VOC-043.02

Drawn by: Nu-Wall

Date: 02/07/2025

Checked by: RL, GT

Scale: 1:2 @ A4